



**REINFORCING SCHEDULE**

WIDTH "W" REINFORCING  
 TO 2'-1" 2 #5  
 2'-2" TO 3'-2" 3 #5  
 3'-3" TO 4'-2" 4 #5  
 ALL SPLICES TO BE LAPPED A MINIMUM OF 18 INCHES

for "T" see plan

**TYPICAL MASONRY WALL FOOTING**  
NOT TO SCALE. APPLICABLE TO MASONRY WALL FOOTINGS NOT OTHERWISE DETAILED.

**GENERAL NOTES:**

1. IT IS THE INTENT OF THE DRAWING FOR THE STRUCTURE TO BE FOUNDED NOT UPON, BUT INTO THE UNDISTURBED EARTH.
2. WHERE INDICATED, UNREINFORCED BRICK WALLS WITH FLOOR ABOVE IS REQUIRED.
3. ALL MASONRY SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE 2008 INTERNATIONAL BUILDING CODE (IBC) AND THE 2008 INTERNATIONAL RESIDENTIAL CODE BOOK (IRC) AS APPLICABLE.
4. STEP WALL FOOTINGS ARE NECESSARY TO BEAK ON UNDISTURBED EARTH.
5. ALL FLOOR SLABS AND WALLS ON GRADE SHALL BE 4" THICK REINFORCED WITH #4 BARS AT 18" ON CENTER WITH #4 BARS PLACED AT MID-DEPTH. PROVIDE 1/2" CLEARANCE FROM ALL ADJACENT SURFACES AND TOP AND BOTTOM REINFORCING SHALL BE LEVEL WITHIN 1/8" IN FEET.
6. WHERE FLOOR IS AN ANGLE OR CONCRETE WALL PROVIDE END BRACKER BY TURNING UP 45 DEGREES FROM WALL.
7. ALL MASONRY SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE 2008 INTERNATIONAL BUILDING CODE (IBC) AND THE 2008 INTERNATIONAL RESIDENTIAL CODE BOOK (IRC) AS APPLICABLE.
8. UNLESS OTHERWISE SPECIFIED, ALL MASONRY SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE 2008 INTERNATIONAL BUILDING CODE (IBC) AND THE 2008 INTERNATIONAL RESIDENTIAL CODE BOOK (IRC) AS APPLICABLE.

**MASONRY OPENINGS:**

4" x 8" x 8"	4 #3 @ 24"
4" x 10" x 8"	4 #3 @ 24"
6" x 8" x 8"	6 #3 @ 24"
6" x 10" x 8"	6 #3 @ 24"